

**Tabela 1.** Temperatura wody sieciowej członu nr 1 i 2 w zależności od temperatury zewnętrznej.

<b>Temperatura zewnętrzna</b>	<b>Człon nr 1 i 2</b>
<b>°C</b>	<b>°C</b>
12	60
11	60
10	60
9	60
8	60
7	60
6	60
5	67
4	70
3	73
2	76
1	79
0	82
-1	85
-2	88
-3	91
-4	94
-5	96
-6	100
-7	102
-8	105
-9	108
-10	111
-11	114
-12	117
-13	120
-14	123
-15	126
-16	129
-17	131
-18	133
-19	136
-20	139